

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 771

Dated 23/07/2026

It is certified that an inspection team headed by JE Chetan Dhamija (Name of officers with designation) from Department Water Supply & Sanitation, Punjab PHED Inspected the Akal Academy Jandiali, Dhandra (Name & address of the school) on 29.07.2026 (Date of inspection) and on the basis of Water Test Report (Attached) bearing on DWTLL/2627/00128 dated 06.08.2026 of District Water Testing Lab Ludhiana (PHED Lab) Certified that the Akal Academy Jandiali, Dhandra (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the School building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till 31.03.2027


Sub Divisional Engineer
Water Supply & Sanitation
Sub Div No. 1, Ludhiana

Signature with Seal.....

Name- Er. Ritika Sallan

Designation- Sub Divisional Engineer

Name & Address of the office/Department-
Department of Water Supply & Sanitation,
Punjab

To

Akal Academy Jandiali, Dhandra
(Name & Address of the Institution)

DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtlabludhiana@gmail.com

To,

S.D.E. , Sub Div. No. - 1
DWSS , Ludhiana

No.: DWTLL/2627/00128 Dated : 06/08/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 598 Dated: 13/07/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 04/08/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Ludhiana

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Ludhiana

DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtlabludhiana@gmail.com



TC-13223

TEST REPORT

Name & Address of Customer : S.D.E. , Sub Div. No. - 1 DWSS , Ludhiana		Customer Reference No.	No : 598 Dated : 13/07/2026
		Sample Submitted by	S.D.E.
		Date of Sample Receipt	04/08/2026
		Analysis Starting Date	04/08/2026
		Analysis completion Date	06/08/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC13223260000096F	Sample Type :	Water
Test Report No.:	DWTLL/2627/00128	Date of Issue :	06/08/2026
Registration no.:	DWTLL/REG2627/00662	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akal Academy Jandiali (Submersible) / NA
Village :	JANDIALI	Habitation :	JANDIALI
Block:	Ludhiana-I	District :	Ludhiana
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.06	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	396	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	336	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	280	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	64	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	29	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	24	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Ludhiana

End of the Test Report



DISTRICT WATER TESTING LABORATORY, LUDHIANA

Water Supply & Sanitation Division no.1, Court Complex, Ludhiana

dwtbludhiana@gmail.com



TC-13223

TEST REPORT

Name & Address of Customer : S.D.E. , Sub Div. No. - 1 DWSS , Ludhiana		Customer Reference No.	No : 598 Dated : 13/07/2026
		Sample Submitted by	S.D.E.
		Date of Sample Receipt	04/08/2026
		Analysis Starting Date	04/08/2026
		Analysis completion Date	06/08/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC13223260000096F	Sample Type :	Treated Water
Test Report No.:	DWTLL/2627/00128	Date of Issue :	06/08/2026
Registration no.:	DWTLL/REG2627/00663	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWFP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akal Academy Jandiali (R.O.) / NA
Village :	JANDIALI	Habitation :	JANDIALI
Block:	Ludhiana-I	District :	Ludhiana
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.88	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	59	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	40	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	24	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	5	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	BDL	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	12	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

(Signature)

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Ludhiana

End of the Test Report

